Danish Indoor Climate Labelling

Certificate no. 132

Danish Indoor Climate Labelling hereby certifies that the product group:

Junckers Water based Maintenance, Furniture and Floor lacquers

Junckers Industrier A/S
Værftsvej 4
DK-4600 Køge
Denmark

has been approved and awarded a labelling license

The labelling license is valid through:
30 November 2026

Danish Indoor Climate Labelling

This certificate is subject to annual renewal according to the procedures of Danish Indoor Climate Labelling.
Danish Indoor Climate Labelling may withdraw the rights to use this certificate in case the manufacturer does not meet the requirements.

Danish Indoor Climate Labelling
Gregersensvej | DK-2630 Taastrup
indeklimamaerket@teknologisk.dk
https://indeklimamaerket.dk

THE INDOOR CLIMATE LABEL

DANISH TECHNOLOGICAL INSTITUTE

Danish Indoor Climate Labelling
Certificate no. 132

Labelling license holder:
Junckers Industrier A/S
Værftsvej 4
DK-4600 Køge
Denmark

Product group	**Junckers Water based Maintenance, Furniture and Floor lacquers**
Testing and labelling criteria	General labelling criteria, 7th edition, May 2021, Semi hard floors, 3rd edition, January 2018
Date of first issue of license	31 August 2016
Tested product(s)	Junckers HP Commercial
Evaluation of product group	**EMISSION CLASS 1**

The labelling license covers products considered to be identical with the tested product regarding emission and particle characteristics as specified by the labelling criteria. For a full list of products covered by the labelling license, see Appendix.

The emission class was determined based on the following measured values:

Emission measured after 28 days		
$TVOC_{28}$	**0.02**	mg/m^3
$Formaldehyde_{28}$	**< 0.005**	mg/m^3

Sensory evaluation		
Time-value	**10**	days

Labelling license basis
The tested product(s) shows compliance with the DICL criteria for the present product group:

Emission measured after 3 days			
TVOC	≤	10	mg/m^3
EU CARC 1A and 1B	≤	0.01	mg/m^3
Emission measured after 28 days			
Sum of TVOC and SVOC with LCI	≤	1.0	mg/m^3
EU CARC 1A and 1B	≤	0.001	mg/m^3
R-value	≤	1	
Sensory evaluation			
Time-value	≤	120	days

Emission Class 1	$TVOC_{28}$	≤	0.5	mg/m^3
	$Formaldehyde_{28}$	≤	0.01	mg/m^3
Emission Class 2	$TVOC_{28}$	≤	1.0	mg/m^3
	$Formaldehyde_{28}$	≤	0.06	mg/m^3
Emission Class 3	$TVOC_{28}$	≤	1.0	mg/m^3
	$Formaldehyde_{28}$	≤	0.1	mg/m^3

Product information requirements
The holder of the labelling license is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor air quality in practice: product specifications, guidelines for transport, storage, assembly, cleaning and maintenance.

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.

Danish Indoor Climate Labelling
Labelling license no. 132

Bilag: Handelsnavne omfattet af mærkningstilladelse
Appendix: Trade names covered by the labelling license
Anlage: Handelsnamen, geregelt über die Lizens

Labelling license holder:
Junckers Industrier A/S
Værftsvej
DK-4600 Køge

Date:	26. marts 2026
Product group:	Junckers Water based Maintenance, Furniture and Floor lacquers Junckers Vandbaserede Pleje-, Møbel- og Gulvlakker

Junckers Grundlak, klar og farvet
Junckers WB Primer, clear and coloured
Junckers Gulvlak
Junckers MT200 Floor lacquer
Junckers LT100 Floor lacquer
Junckers Møbellak, vandbaseret
Junckers Gulvlak Plus
Junckers MT500 Floor lacquer
Junckers HT600 Floor lacquer
Junckers PUR Floor sealer
Junckers HT700 Floor lacquer
Junckers MT300 Floor lacquer
Junckers HP800 Sport
Junckers HP Sport Linemarking, all colours
Junckers PUR Floor colour
Junckers Friction Floor lacquer
Junckers PUR Primer
Junckers TB Primer

For *Danish Indoor Climate Labelling*

26.03.26
Date Signature

For *Junckers Industrier A/S*

27-03-2026
Date Signature

Danish Indoor Climate Labelling
Gregersensvej | DK-2630 Taastrup
indeklimamaerket@teknologisk.dk
https://indeklimamaerket.dk

THE INDOOR CLIMATE LABEL

DANISH TECHNOLOGICAL INSTITUTE